

CERTIFICATE

QA-AC-7849/26

QA TECHNIC - ATTESTATION OF CONFORMITY

2006/42/EC MACHINERY DIRECTIVE

2014/35/EU LOW VOLTAGE DIRECTIVE

2014/30/EU ELECTROMAGNETIC COMPATIBILITY DIRECTIVE

WORIMEX CO. HVAC INDUSTRY AND TRADE INC.

Osmangazi Neighborhood, 3121st Street, No: 5/2, Esenyurt, Istanbul, Turkey.

Product (s)	: Circulation Pump
Product Type (s) / Model (s)	: As per Annex
Applicable EC Directive (s)	: 2006/42/EC, 2014/35/EU, 2014/30/EU
Applicable Harmonized Standard(s)	: EN 60335-1:2012+A11:2014+A13:2017+A1:2019+A14:2019+A2:2019+A15:2021+A16:2023; EN IEC 60335-2-51:2023+A11:2023; EN 62233:2008+AC:2008; EN IEC 55014-1:2021; EN IEC 55014-2:2021; EN IEC 61000-3-2:2019/A2:2024; EN 61000-3-3:2013+A1:2019+A2:2021; EN 809:1998+A1:2009+AC:2010

Test Report / TCF (s) and Date (s) : Ningbo Tongpu Testing Technology Co., Ltd.
TP260331TF01/S-0536; 28.04.2026
TP260331TF02/M-0536; 28.04.2026
TP260331TF03/E-0536; 28.04.2026

The Present certificate is valid just for the analysed product design. The certificate shall lose its validity in case of any changes in the product. Ultimate responsibility related with conformity of product with directive / directives, belongs to the manufacturer.


Ultimate responsibility regarding the affixing of CE mark according to relevant regulations and legal legislation, belongs to the manufacturer.

Certificate Issue Date : 5.5.2026

Certificate Expiry Date: 5.5.2031

**ALBERK QA INTERNATIONAL TECHNICAL
CONTROL AND CERTIFICATION INC.**

Küçükbakkalköy Mahallesi
Kayışdağı Caddesi
No: 13 İç Kapı No: 1
Ataşehir / İstanbul / TÜRKİYE


Latif Murat YILMAZ
General Manager

Tel : 0216 572 49 10-11-12
Fax : 0216 572 49 14

www.qatechnic.com



for business improvement®

www.gatechnic.com

info@gatechnic.com

QA-AC-7849/26

Annex

No.	Model	Rated voltage (V)	Rated frequency (Hz)	Power (W)	Hmax (m)	Qmax (L/min)	I.C.	IP
1	DXS 60-180 DN25	220-240	50/60	96	6	56	H	44
2	DXS 60-180 DN32	220-240	50/60	94	6	62	H	44
3	DXS-B 60-180 DN25	220-240	50/60	94	6	55	H	44
4	DXM 70-180 DN25	220-240	50/60	186	7	80	H	44
5	DXM 70-180 DN32	220-240	50/60	191	7	104	H	44
6	DXM80-130 DN25	220-240	50/60	237	8	95	H	44
7	DXM80-180 DN25	220-240	50/60	237	8	95	H	44
8	DXM80-180 DN32	220-240	50/60	239	8	129	H	44
9	DXL 110-180 DN32	220-240	50/60	365	11	122	H	44
10	3BE 50-250 DN40	220-240	50/60	187	5	120	H	44
11	3BE 100-220	220-240	50/60	400	10	275	H	44
12	3BE 120-220	220-240	50/60	550	12	300	H	44
13	3BE 150-220	220-240	50/60	650	15	324	H	44
14	3BE 180-220	220-240	50/60	800	18	350	H	44
15	3BE 100-280	220-240	50/60	400	10	133	H	44
16	3BE 120-280	220-240	50/60	650	12	467	H	44
17	3BE 150-280	220-240	50/60	650	15	324	H	44
18	3BE 180-280	220-240	50/60	1200	18	600	H	44
19	3BE 100-340	220-240	50/60	400	10	133	H	44
20	3BE 120-340	220-240	50/60	830	12	641	H	44
21	3BE 150-340	220-240	50/60	650	15	324	H	44
22	3BE 180-340	220-240	50/60	1200	18	800	H	44
23	3BE 100-360	220-240	50/60	400	10	133	H	44
24	3BE 120-360	220-240	50/60	830	12	641	H	44
25	3BE 150-360	220-240	50/60	650	15	324	H	44

Latif Murat YILMAZ

ALBERK QA INTERNATIONAL TECHNICAL CONTROL AND CERTIFICATION CORPORATION

ADDRESS: KÜÇÜKBAKKALKÖY DISTRICT

KAYIŞDAĞI STREET

TAHSİN ARICI BUSINESS CENTER

BUILDING NUMBER 13 FLOOR 1 FLAT 4

ATAŞEHİR/İSTANBUL/TÜRKİYE

TEL : + 90 216 572 49 10 (pbx)

FAKS : + 90 216 572 49 14



for business improvement®

www.gatechnic.com

info@gatechnic.com

QA-AC-7849/26

Annex

No.	Model	Rated voltage (V)	Rated frequency (Hz)	Power (W)	Hmax (m)	Qmax (L/min)	I.C.	IP
26	3BE 180-360	220-240	50/60	1200	18	800	H	44
27	COSMO+ 25-60	220-240	50/60	90	6	100	H	44
28	COSMO+ 25-80	220-240	50/60	120	8	108	H	44
29	COSMO+ 25-90	220-240	50/60	140	9	113	H	44
30	COSMO+ 25-100	220-240	50/60	150	10	117	H	44
31	COSMO+ 25-120	220-240	50/60	180	12	125	H	44
32	COSMO+ 25-140	220-240	50/60	200	14	125	H	44
33	COSMO+ 25-150	220-240	50/60	220	15	125	H	44
34	COSMO+ 25-160	220-240	50/60	240	16	133	H	44
35	COSMO+ 25-180	220-240	50/60	260	18	133	H	44
36	COSMO+ 25-200	220-240	50/60	350	20	167	H	44
37	COSMO+ 32-60	220-240	50/60	90	6	116	H	44
38	COSMO+ 32-80	220-240	50/60	120	8	125	H	44
39	COSMO+ 32-90	220-240	50/60	140	9	129	H	44
40	COSMO+ 32-100	220-240	50/60	150	10	133	H	44
41	COSMO+ 32-120	220-240	50/60	180	12	141	H	44
42	COSMO+ 32-140	220-240	50/60	200	14	141	H	44
43	COSMO+ 32-150	220-240	50/60	220	15	141	H	44
44	COSMO+ 32-160	220-240	50/60	240	16	183	H	44
45	COSMO+ 32-180	220-240	50/60	260	18	183	H	44
46	COSMO+ 32-200	220-240	50/60	350	20	200	H	44
47	COSMO+ XL 100-220	220-240	50/60	120	10	150	H	44
48	COSMO+ XL 120-220	220-240	50/60	150	12	158	H	44
49	COSMO+ XL 150-220	220-240	50/60	180	15	167	H	44
50	COSMO+ XL 180-220	220-240	50/60	220	18	183	H	44

Latif Murat YILMAZ

ALBERK QA INTERNATIONAL TECHNICAL CONTROL AND CERTIFICATION CORPORATION

ADDRESS: KÜÇÜKBAKKALKÖY DISTRICT

KAYIŞDAĞI STREET

TAHSİN ARICI BUSINESS CENTER

BUILDING NUMBER 13 FLOOR 1 FLAT 4

ATAŞEHİR/İSTANBUL/TÜRKİYE

TEL : + 90 216 572 49 10 (pbx)

FAKS : + 90 216 572 49 14



for business improvement®

www.gatechnic.com

info@gatechnic.com

QA-AC-7849/26

Annex

MODEL LIST								
No.	Model	Rated voltage (V)	Rated frequency (Hz)	Power (W)	Hmax (m)	Qmax (L/min)	I.C.	IP
51	COSMO+ XL 100-280	220-240	50/60	120	10	150	H	44
52	COSMO+ XL 120-280	220-240	50/60	150	12	158	H	44
53	COSMO+ XL 150-280	220-240	50/60	180	15	167	H	44
54	COSMO+ XL 180-280	220-240	50/60	220	18	183	H	44
55	COSMO+ XL 100-340	220-240	50/60	120	10	150	H	44
56	COSMO+ XL 120-340	220-240	50/60	150	12	158	H	44
57	COSMO+ XL 150-340	220-240	50/60	180	15	167	H	44
58	COSMO+ XL 180-340	220-240	50/60	220	18	183	H	44
59	COSMO+ XL 100-360	220-240	50/60	120	10	150	H	44
60	COSMO+ XL 120-360	220-240	50/60	150	12	158	H	44
61	COSMO+ XL 150-360	220-240	50/60	180	15	167	H	44
62	COSMO+ XL 180-360	220-240	50/60	220	18	183	H	44
63	WB 15-5	220-240	50/60	90	5	17	H	44
64	WB 15-6	220-240	50/60	90	6	33	H	44
65	WB 15-7	220-240	50/60	90	7	33	H	44
66	GB 15-50	220-240	50/60	85	5	17	H	44
67	GB 15-60	220-240	50/60	90	6	33	H	44
68	GB 15-65	220-240	50/60	90	7	33	H	44
69	WBR 12-6	220-240	50/60	90	6	17	H	44
70	WBW 15-5	220-240	50/60	85	5	17	H	44
71	WBW 15-7	220-240	50/60	90	7	33	H	44
72	SB 15-50	220-240	50/60	85	5	17	H	44
73	SB 15-60	220-240	50/60	90	6	17	H	44
74	NB 15-6	220-240	50/60	90	6	17	H	44
75	DSB 15-6	220-240	50/60	90	6	17	H	44

Latif Murat YILMAZ

ALBERK QA INTERNATIONAL TECHNICAL CONTROL AND CERTIFICATION CORPORATION

ADDRESS: KÜÇÜKBAKKALKÖY DISTRICT
KAYIŞDAĞI STREET
TAHSİN ARICI BUSINESS CENTER
BUILDING NUMBER 13 FLOOR 1 FLAT 4
ATAŞEHİR/İSTANBUL/TÜRKİYE

TEL : + 90 216 572 49 10 (pbx)
FAKS : + 90 216 572 49 14



for business improvement®

www.gatechnic.com

info@gatechnic.com

QA-AC-7849/26

Annex

MODEL LIST								
No.	Model	Rated voltage (V)	Rated frequency (Hz)	Power (W)	Hmax (m)	Qmax (L/min)	I.C.	IP
76	DB 15-7.5	220-240	50/60	90	7	33	H	44
77	TRE3S 15-50	220-240	50/60	45	5	47	H	44
78	TRE3S 15-60	220-240	50/60	55	6	50	H	44
79	TRE3M 15-40	220-240	50/60	30	4	43	H	44
80	TRE3M 15-50	220-240	50/60	45	5	47	H	44
81	TRE3M 15-60	220-240	50/60	55	6	50	H	44
82	TRE3M 15-70	220-240	50/60	65	7	58	H	44
83	TRE3M 25-40	220-240	50/60	30	4	43	H	44
84	TRE3M 25-60	220-240	50/60	55	6	50	H	44
85	TRE3M 25-80	220-240	50/60	70	8	63	H	44
86	TRE3M 32-40	220-240	50/60	30	4	43	H	44
87	TRE3M 32-60	220-240	50/60	55	6	50	H	44
88	TRE3M 32-80	220-240	50/60	70	8	63	H	44
89	TRE3L 25-80	220-240	50/60	70	8	72	H	44
90	TRE3L 25-90	220-240	50/60	80	9	77	H	44
91	TRE3L 25-100	220-240	50/60	95	10	80	H	44
92	TRE3L 32-80	220-240	50/60	70	8	72	H	44
93	TRE3L 32-90	220-240	50/60	80	9	77	H	44
94	TRE3L 32-100	220-240	50/60	95	10	80	H	44

Latif Murat YILMAZ

ALBERK QA INTERNATIONAL TECHNICAL CONTROL AND CERTIFICATION CORPORATION

ADDRESS: KÜÇÜKBAKKALKÖY DISTRICT
KAYIŞDAĞI STREET
TAHSİN ARICI BUSINESS CENTER
BUILDING NUMBER 13 FLOOR 1 FLAT 4
ATAŞEHİR/İSTANBUL/TÜRKİYE

TEL : + 90 216 572 49 10 (pbx)
FAKS : + 90 216 572 49 14